ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿಯಮಿತ
BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

13 OCT 2017

TEST CERTIFICATE

Date : _____

This is to certify that the meter received from **M/s. Landis+Gyr Limited** is tested good. It is sealed in the MT laboratory having the Meter & Seal details as below.

Meter Details :

Make	:	Landis+Gyr	3P, 4W, Whole Current	3 x 240V (L-N)
Type	:	ZMI310	4000 Imp/kWh	5-30A
Class	:	1.0	50 Hz.	

Sl. No.: CS18004. initial reading 00000

The meter is sealed with Polycarbonate seal with Sl. No. BMB 37542.

Asst. Executive Engg. (Ele.),
BMAZ, BESCOM,
Bangalore.

Ref: 1) Application No:892863370080 Dated: 16-10-2017
2) Account ID : 9703527435
3) Prevailing KERC regulations.

With reference to your Application No. **892863370080 Dated: 16-10-2017**, power supply to an extent of **0 KW** and **5 HP** on Account ID **9703527435** under LT basis, is hereby sanctioned, subject to the following:

1. Details of your building/premises:

   a. **Plinth area:**

1	No. of Floors Existing	0
2	No. of Floors Added or New	0
3	Existing Plinth Area in sq.m.	0
4	Added or New Plinth Area in sq.m.	0
5	**Total Plinth Area in sq.m.**	0

   b. Total height of the building above ground level in m: **0**

2. The **PROPOSED** Sanctioned Load of your building is **3.73 KW**

   Existing Load Details of your premises:

1	Existing Sanctioned Load	0
2	New/ Additional Load Required	0 KW and 5 HP
3	Total Load	3.73 KW